

**Portable Appliance Testing Results**

**Location: Ugley Village Hall, Cambridge Road, Ugley CM22 6HR**

**Date of Testing: 21 Nov 2023**

<b>Equip't No.</b>	<b>Description</b>	<b>Location</b>	<b>Make or Serial No.</b>	<b>Visual Checks</b>	<b>Earth Bond Ohm</b>	<b>Insulation Mohm</b>	<b>Lead Checks</b>	<b>Status</b>
UVH/1	Kettle	Kitchen	Tesco	Pass	—	>20	Pass	Pass
UVH/2	Kettle	Kitchen	Tesco	Pass	—	>20	Pass	Pass
UVH/3	Microwave	Kitchen	Goodmans	Pass	0.02	>20	Pass	Pass
UVH/4	Vacuum Cleaner	Kitchen	Vax	Pass	N/A	>20	Pass	Pass
UVH/5	Kettle	Kitchen	Tesco	Pass	—	>20	Pass	Pass
UVH/6	Fridge	Kitchen	Fridgemaster	Pass	0.03	>20	Pass	Pass
UVH/7	Water Urn	Store	Cygnnet	Pass	0.00	>20	Pass	Pass
UVH/8	Extractor Hood	Kitchen	—	Pass	N/A	>20	Pass	Pass
UVH/9	Hotplate	Kitchen	Salton	Pass	—	>20	Pass	Pass
UVH/10	Vacuum Cleaner	Kitchen	Breeze	Pass	N/A	>20	Pass	Pass

**WE RECOMMEND THAT PORTABLE APPLIANCE TESTING IS CARRIED OUT ON A REGULAR BASIS  
ACCORDING TO THE TYPE OF EQUIPMENT AND LEVEL OF USAGE WITHIN THE VILLAGE HALL**

**Note: UVH/5 - Showing signs of corrosion**

Inspected & Tested by  (Heather Scadden)

