

# AJ4 Electrical Ltd

## Electrical Contractors

15 The Dreys, Swards End  
Saffron Walden CB10 2LL  
Phone: 07792 602159

### Portable Appliance Testing Results

**Location: Ugley Village Hall, Cambridge Road, Ugley CM22 6HR**

**Date of Testing: 21 Nov 2023**

| Equip't No. | Description      | Location | Make or Serial No. | Visual Checks | Earth Bond Ohm | Insulation Mohm | Lead Checks | Status |
|-------------|------------------|----------|--------------------|---------------|----------------|-----------------|-------------|--------|
| UVH/1       | Kettle           | Kitchen  | Tesco              | Pass          | —              | >20             | Pass        | Pass   |
| UVH/2       | Kettle           | Kitchen  | Tesco              | Pass          | —              | >20             | Pass        | Pass   |
| UVH/3       | Microwave        | Kitchen  | Goodmans           | Pass          | 0.03           | >20             | Pass        | Pass   |
| UVH/4       | Transformer Plug | Kitchen  | Gigaclear          | Pass          | N/A            | —               | Pass        | Pass   |
| UVH/5       | Kettle           | Kitchen  | Tesco              | Pass          | —              | >20             | Pass        | Pass   |
| UVH/6       | Fridge           | Kitchen  | Fridgemaster       | Pass          | 0.04           | >20             | Pass        | Pass   |
| UVH/7       | Water Urn        | Store    | Cygnnet            | Pass          | 0.02           | >20             | Pass        | Pass   |
| UVH/8       | Extractor Hood   | Kitchen  | —                  | Pass          | N/A            | >20             | Pass        | Pass   |
| UVH/9       | Transformer Plug | Kitchen  | Gigaclear          | Pass          | N/A            | —               | Pass        | Pass   |
| UVH/10      | USB Charger      | Kitchen  | Hive               | Pass          | N/A            | —               | —           | Pass   |
| UVH/11      | Kettle           | Kitchen  | Bosch              | Pass          | —              | >20             | Pass        | Pass   |
| UVH/12      | Transformer Plug | Hall     | Hive               | Pass          | N/A            | —               | —           | Pass   |
| UVH/13      | Transformer Plug | Stage    | Hive               | Pass          | N/A            | —               | —           | Pass   |

**WE RECOMMEND THAT PORTABLE APPLIANCE TESTING IS CARRIED OUT ON A REGULAR BASIS  
ACCORDING TO THE TYPE OF EQUIPMENT AND LEVEL OF USAGE WITHIN THE VILLAGE HALL**

**Note: UVH/5 - Showing signs of corrosion**

**Inspected/Tested by H. Scadden**

