



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Ugley Village Hall 26

Certificate No: Jrand1476

Engineers Details

Trading Title Harpers Heating & Plumbing Ltd

Address Unit i4 Peek Business Centre
Woodside, Dunmow Road
Bishops Stortford

Post Code: CM23 5RG

Gas Safe No: 117551

Telephone No: 01279771981

Installation Details

Installation Address Tenant
Ugley Village Hall
Cambridge Road
Ugley

Post Code: CM22 6HR

Client Details

Client Address Tenant
Ugley Village Hall
Cambridge Road
Ugley

Post Code: CM22 6HR

Telephone No:

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Flue Type (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Cooker	Unknown	Na	Na	Na	20 mb	Na	YES	FL	YES	YES	YES	NA	NA	NA	YES
2	Store Cupboard	Combi boiler	Worcester	Greenstar 4000 25 C	0.0006	9.1	17.90 mb	54	YES	RS	YES	YES	YES	YES	PASS	YES	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve
Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON
OR BEFORE:

Tue-22-06-2027

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

NA

Signatures

Report Issued By:

Name: John Randfield

Signed:

Date: Mon-22-06-2026

Report Received By:

Name:

Signed:

Date: Mon-22-06-2026

Gas ID Number: 5091117